



TOWN OF CHESHIRE
DEPARTMENT OF PUBLIC WORKS/ENGINEERING
84 SOUTH MAIN STREET, CHESHIRE, CONNECTICUT 06410
Telephone (203) 271-6650 Fax (203) 271-6659

Addendum #1

MIXVILLE PARK PRE-ENGINEERED METAL BUILDING
Bid #2122-05
Date: 1/31/22

QUESTION/ANSWER:

Question: Where is the septic?

Answer: The existing septic tank is located in front of existing bathrooms and existing leaching field about 30 ft. east of the tank.

Question: What type of paving? Conc pavers, concrete or asphalt?

Answer: Concrete pavers.

Question: Will an A-2 survey be required?

Answer: Yes, and As-built drawings.

Question: Does the Town have a survey of the existing site?

Answer: Yes, but only area around the existing bathrooms.

Question: Are gutters and downspouts required?

Answer: No, but diverters on roof at the locations of the exit doors

Question: If gutters and downspouts are required, where will they drain to?

Answer: No.

Question: Will a subsurface storm water system be required?

Answer: No.

Question: What pitch shall the roof be?

Answer: Roof pitch 4/12.

Question: Where will electrical power come from?

Answer: From existing service panel located on all of adjacent existing canopy.

Question: Is there a geotechnical report?

Answer: No.



TOWN OF CHESHIRE
DEPARTMENT OF PUBLIC WORKS/ENGINEERING
84 SOUTH MAIN STREET, CHESHIRE, CONNECTICUT 06410
Telephone (203) 271-6650 Fax (203) 271-6659

Question: How deep are the existing foundations?

Answer: No information.

Question: How do we know how much soil is unsuitable and/or fill material?

Answer: No information.

(attachment - existing septic plan Mixville Park)

End of Addendum #1

Addendum #2

MIXVILLE PARK PRE-ENGINEERED METAL BUILDING

Bid #2122-05

Date: 2/4/22

QUESTION/ANSWER:

Question: Will heating and air conditioning be required?

Answer: No.

Question: Will the Town waive the permit fees?

Answer: Yes.