



TOWN OF CHESHIRE  
DEPARTMENT OF PUBLIC WORKS/ENGINEERING  
84 SOUTH MAIN STREET, CHESHIRE, CONNECTICUT 06410  
Telephone (203) 271-6650 Fax (203) 271-6659

---

## **Addendum #4**

MIXVILLE PARK PRE-ENGINEERED METAL BUILDING  
Bid #2122-05  
Date: 2/18/22

---

### **QUESTION/ANSWER:**

**Question:** Is this project prevailing wage?

**Answer:** Prevailing wage limit for new construction is a minimum \$1,000,000.00

**Question:** Are we to carry SBE/MBE requirements?

**Answer:** No SBE/MBE requirements.

**Question:** Page 6 of 11 states Alternate for 8" CMU with concrete veneer. Alternate also includes interior of metal panel wall from top of masonry to 12 feet above finish floor has 2 x 4 @ metal stud framing with 5/8" gyp board. Question: are we to also include 2 x 4 @ 16 stud framing with gyp board for the base bid? Are we then to carry FRP 3' – 4" high on the gyp board?

**Answer:** Base bid: all exterior walls to be metal panels. Alternate: masonry up to 3' 4" A.F.F. with stone veneer on outside and painted inside. Metal framing with 5/8" gyp. Bd. On top of masonry up to 12' A.F.F.

**Question:** Are we to include drywall and FRP on all walls for base bid-that do not have masonry low wall?

**Answer:** See above.

**Question:** Are we to include liner panels if we have drywall on the interior?

**Answer:** No.

**End of Addendum #4**