

TOILET ROOM UPGRADES

**DOOLITTLE ELEMENTARY SCHOOL
735 CORNWALL AVENUE
CHESHIRE, CT 06410
BID #2223-09**

S/P+A PROJECT NO. 20.072

DATE: November 22, 2022

The following changes to the Drawings and Project Specifications shall become a part of the Drawings and Project Specifications; superseding previously issued Drawings and Project Specifications to the extent modified by Addendum #2.

General Information:

- The deadline for RFIs is Monday, November 21, 2022.
- See attached RFI log. (1)

Changes to Addenda:

- ADDENDUM #1, Changes to the Drawings, DRAWING E101, TOILET ROOM ELECTRICAL PLANS & NOTES, Classroom 14 & 15 Floor Plan 2, Toilet 15A, revise “EF-2” to read “EF-3”.

The bid date remains unchanged by this addendum.

The addendum consists of two (2) pages of 8½” x 11” text.
End of ReBid Addendum #2



SILVER PETRUCELLI + ASSOCIATES
3190 Whitney Avenue | Hamden CT 06518
311 State Street | New London CT 06320

BID RFI LOG

Project: **Doolittle ES Toilet Room Upgrades REBID**
State Project/Bid #: **2223-09**
S/P+A Project #: **21.336**

RFI Deadline: **11/21/22**
Bids Due: **11/30/22**

RFI #	QUESTION	DATE RECEIVED	RESPONSE	ADDENDUM # ISSUED
001	For alternates 1 and 2 can a distance to electrical panel LPD be provided?	11/18/22	The location of the panel in relation to the area of work is shown on the keyplan for reference. Routing & distances are to be verified in the field.	2
002	For the base bid can a distance to electrical panel RP1 be provided?	11/18/22	The location of the panel in relation to the area of work is shown on the keyplan for reference. Routing & distances are to be verified in the field.	2
003	For the base bid, a call for assistance switch and light is only shown for the faculty bathroom. Will there also be one in each of the boys and girls bathrooms?	11/18/22	Call for aid devices are only required at Staff Toilet 156 under the base bid scope of work.	2
004	For the base bid and alternates 1 and 2, are any of the sinks, toilets, or urinals to have automatic valves, if so batteries or hardwired?	11/18/22	Please refer to Construction Note #5 on Drawing E101 and the Plumbing Fixture/Equipment Schedule on Drawing P901.	2
005	On page E-101 for alternates 1 and 2, in the little closets an exhaust fan is shown to be removed and a new one installed, yet this same exhaust fan is not identified anywhere and does not appear on the mechanical drawings. Could you confirm the specs for this exhaust fan?	11/18/22	The exhaust fans located in the existing classroom toilet rooms are to be removed. New exhaust fans EF-2 & EF-3 are to be provided in the new classroom toilet rooms, refer to Drawing M101 and schedules on Drawing M201. The existing classroom toilets being converted to closets will not have an exhaust fan. Please note that on Drawing 2/E101, the exhaust fan in Toilet 15A should be labeled "EF-3".	2
006	Please provide information on the Fire Alarm Panel manufacturer.	11/18/22	The existing Fire Alarm Panel is a Simplex 4100 with a Notifier NFS320 and FireLite digital communicator.	2
007	What are the existing ceiling heights at the base bid toilet rooms?	11/18/22	Please refer to ceiling heights noted on Drawing 3/A101. Ceiling heights are intended to match the existing ceiling heights (V.I.F.).	2